



ELECTRICAL RULES & REGULATIONS

Before any equipment can be hooked up electrically, all equipment must have a CSA approval sticker or a local approval from the Office of the Fire Commission – Phone 204-945-3373. All electrical connections, installations, assemblies, motors or any electrical operating gear must conform to all federal, provincial, and local electrical and fire codes.

All services are sold on a per booth or per exhibitor basis. The connection in a booth cannot be shared.

Wall, column and permanent building utility outlets are not part of booth space and are not to be used by the exhibitor unless specified otherwise.

The service provided includes installation of temporary power lines to the booth, maintenance during the show, electrical energy and removal of service at the conclusion of the event. However, it does not include connecting/ disconnecting to exhibitors equipment.

One standard double electrical Service supplies a maximum of 15 amps of electrical power at 120 volts. When exhibitor requirements exceed 15 amps, additional units must be ordered to prevent overloading. Exhibitors shall be prohibited from overloading electrical circuits regardless of voltage and amperage. Overloading of circuitry due to equipment failure will be excusable only on the first interruption of power. Equipment must not be restarted until a “RBC CCW Electrician” has checked equipment for source of problem and corrected malfunction. Such device to be a part of the equipment or may be installed as part of the initial installation. When approved by a “RBC CCW Electrician” normal circuit protection will be adequate.

Installations of 208 or 600 volt service require a drawing of your exhibit space detailing machine positions and electrical connections.

Under no circumstances shall anyone other than the “RBC CCW Electrician” or a licensed electrical contractor who has been given permission by the RBC Convention Centre Winnipeg make electrical connections or disconnections. Supplying of services by outside contractors within the RBC Convention Centre Winnipeg may result in a fee charged to the supplier or client.

The RBC Convention Centre Winnipeg reserves the right to check and inspect any and all electrical connections, equipment and facilities which any customer uses while in the Centre. “RBC CCW Electrician” may at any time check voltage and amperage at any booth. Any discrepancy found on electrical systems must be corrected immediately or power shall be discontinued.

All complaints must be presented by the exhibitor before the close of the exhibition in order to be properly investigated.

Special equipment requiring company engineers or technicians for assembly, servicing, preparatory work, and operation may be executed without “RBC CCW Electrician”, however, all service connections and overload protection to such equipment must be made by “RBC CCW Electrician” only.

All equipment must be properly tagged and wired with complete information as to type of current, voltage, phase, cycle, horsepower, etc.

All material and equipment furnished by the RBC Convention Centre for this service order shall remain the RBC Convention Centre’s property and shall be removed only by the Convention Centre at the close of the show.

Unless otherwise directed, the “RBC CCW Electricians” are authorized to cut floor coverings to permit installation of service.